

การบำรุงรักษาแผ่นกรองอากาศ

	ประเภทแผ่นกรองอากาศ	Initial Resistance	Recommend Final	Service Time	Wash or	Replacement
		in. WG.	Resistance in. WG.	(Weeks)	Replace	Months
Pre Filter	Aluminium Filter	0.05	0.5 - 1	1 to 2	wash	12 to 24
	Washable Synthetic Media (Flat)	0.5	1	1 to 2	wash	12
	Washable Synthetic Media (Corrugated)	0.2	1	1 to 2	wash	12
	Max Pre Pleat (Disposable) MERV 7	0.3	1	NA	replacement	3 to 12
	Max Fresh Air; โยสังเคราะห์เคลือบคาร์บอน	0.3	1	NA	replacement	3 to 12
Medium Filter	Max Pocket	0.5	1.5	NA	replacement	6 to 12
	Maxi Flow I	0.6	1.5	NA	replacement	6 to 12
	Maxi Flow II Slim	0.75	1.5	NA	replacement	6 to 12
	Maxi-Plus 2V - 4V	0.5 and 0.36	1.5	NA	replacement	6 to 12
	Duramax	0.6	1.5	NA	replacement	6 to 12
	Max GTS	0.5	1.5	NA	replacement	6 to 12
HEPA Filter	HEPA Max Separators Type	1	2	NA	replacement	12
	HEPA Max Slim (Mini-Pleat)	0.5	1	NA	replacement	12
	HEPA Max: High Capacity	0.45	2	NA	replacement	12
	HEPA Max Ceiling Module	0.5	1	NA	replacement	12
Gas Phase	Maxi Pure ชนิดต่างๆ	0.5	0.5	NA	replacement	3 to 12

AIRMAX reserves our right to change design and specifications without notice.